



**AgEcon** SEARCH  
RESEARCH IN AGRICULTURAL & APPLIED ECONOMICS

*The World's Largest Open Access Agricultural & Applied Economics Digital Library*

**This document is discoverable and free to researchers across the globe due to the work of AgEcon Search.**

**Help ensure our sustainability.**

Give to AgEcon Search

AgEcon Search  
<http://ageconsearch.umn.edu>  
[aesearch@umn.edu](mailto:aesearch@umn.edu)

*Papers downloaded from **AgEcon Search** may be used for non-commercial purposes and personal study only. No other use, including posting to another Internet site, is permitted without permission from the copyright owner (not AgEcon Search), or as allowed under the provisions of Fair Use, U.S. Copyright Act, Title 17 U.S.C.*


***Abstract***

*Water scarcity is a problem of increasing concern for the state of Georgia. For the last three decades the state has experienced droughts that have reached extreme conditions on many occasions. Georgia released a comprehensive water plan in 2008 that outlined historical and projected water use for various sectors of the economy. Water use for energy generation has the largest by volume consumptive use of water in the state. The report outlined plans for future energy generating facilities in order to meet the projected demand increase for electricity due to population growth over the next 30 years. The planned technologies for these power plants relied mostly on conventional fossil fuel generators with tower cooling systems. From a water consumption standpoint these facilities are highly inefficient compared to currently available technologies. Though a quantitative analysis of the median water consumption rates of alternative fuel sources and cooling technologies and a qualitative analysis of the feasibility of these alternatives from a geographical perspective, it was determined that concentrated solar power and adoption of dry cooling technology for conventional combustion generators provided the greatest water savings (96-99% on average) relative to other generation technologies. It was also concluded that the choice in cooling technology had nearly as much impact on water consumption by a power plant as did the choice of a fuel source.*

For the last five years Georgia has seen increases in the areas affected by extreme drought conditions, starting in 2007 with a major drought that garnered national media attention. However, droughts have posed a threat to Georgians for over 30 years. These climactic changes have created greater hardship due to legal conflicts with neighboring Florida and Alabama over the two major river basins located in the state. Additionally, the metropolitan Atlanta area has seen a large population increase in the last decade, which has increased demand for water (U.S. Census, 2010). Throughout the droughts and interstate conflicts, Georgia attempted to mitigate some of this water scarcity through legislation, interstate compacts, and conservation measures. Despite these attempts, the most recent dry period resulted with over half the state declared to be in extreme drought in 2012.

Georgia has not seen any major shifts in the allocation of water resources in the last 20-30 years. As depicted in Figure 1, since 1985, thermoelectric power has been by far the largest water use in the state. The changes in irrigation withdrawals are consistent with variances in hydrological conditions, increasing during drier years (1980 and 2000) and decreasing during normal or wetter years, and therefore do not indicate a larger economic trend toward or away from certain industries and water uses (Fanning, 2009).


**Figure 1.** Trends in total water use by category, Georgia 1980-2005



Source: Fanning, 2009. Georgia Environmental Protection Division


In the United States, approximately eighty-nine percent of electricity is generated in thermoelectric power plants. Another nine percent comes from hydroelectric generation and the remaining two percent comes from wind and solar energy. In Georgia the energy generation portfolio is similar to the national figures. Ninety-five percent of the state's electricity comes from thermoelectric sources (coal, gas, nuclear) and the remaining five percent from hydroelectric generation (Energy Information Administration, 2012). Additionally, Georgia is ranked ninth highest in the nation in both electricity generation and consumption. One of the costs not adequately accounted for in our power supply portfolio is the water use of these power plants. Figures 2 and 3 illustrate the withdrawals for thermoelectric power in Georgia and the level of consumptive water use in different counties.

**Figure 2. Consumptive Water Use by County**



Source: U.S. Geological Survey 2009


**Figure 3. Thermoelectric Water Withdrawals by County**



Source: U.S. Geological Survey 2009

Differentiated from aggregate water withdrawals, this paper will focus on the water use that is evaporated, transpired or otherwise removed from the immediate water environment. The maps above illustrate that there is a great deal of overlap between the counties with the highest withdrawals for thermoelectric power and those with the highest consumptive water uses. In Georgia consumptive water use accounts for approximately 24% of total water disposition with the breakdown of use by category illustrated in the figures below.

**Figure 4.** Areas Represent a Percent of the Total Water Consumption in Georgia<sup>a</sup>



Note: <sup>a</sup> The median thermoelectric water use rate was used due to the variability in cooling technologies which can have dramatically different water consumption rates from 0-70%.

Thermoelectric power is responsible for 35-50% of consumptive water use in Georgia which is the largest share of any of the categories. Though irrigation and livestock have a larger water consumption factor of 100%, compared to the 18% and 35% factors used for thermoelectric power in constructing the figures above, the total volume of water withdrawn by power plants far outpaces agricultural withdrawals (USGS 2009).

The nature of electricity production and distribution under the grid system warrants oversight and control by the government. Because much of Georgia remains rural, and urban sprawl fuels the growth of suburban neighborhoods, the demand for electricity follows this

growth. Providing reliable service to these neighborhoods incurs a significant cost that may or may not be profitable for the utility company. Thus, to encourage the electric companies to provide service and to ensure that citizens have power, Georgia has given Georgia Power and a handful of electric membership corporations (EMCs) monopolistic control over the state's electricity market. Currently there are 11 new power generation facilities planned to come online in the next 5-10 years in order to keep up with increasing electricity demand (Davis and Horrie, 2010). Most are slated to use conventional, fossil fuel technologies, and this paper will explore opportunities for water conservation through alternative fuel or cooling technology adoption.

The opportunity costs of water conservation during periods of drought will have differing impact on water consumers in various sectors (power generation, industry, agriculture, and residential users). Without a conservation strategy, prices will necessarily rise as demand for an increasingly scarce resource grows. In fact, according to a recent study by the Environmental Finance Center at the University of North Carolina, Georgia's water utilities are already under financial stress. The 2012 report revealed that many water suppliers are not covering their operating expenses, making it difficult update aging infrastructure or finance necessary expansion (EFC, 2012). The proposed power plants fall under five different regional water planning councils (depicted in table 1) and reports released by these individual authorities in 2010 projected significant increases in municipal water demand over the next 40 years with moderate to severe water shortages resulting.

**Table 1.** Proposed Power Plant Location and Projected Regional Water Demand

| <b>River Basin<br/>Commission</b> | <b>Power Plants</b>  | <b>Municipal Demand Increase<br/>2010-2050</b> | <b>Water shortage</b>                     |
|-----------------------------------|--|--|---|
| Upper Ocmulgee Watershed          | Oglethorpe Power   | 11%  | 20 million gallons per day                |
| Upper Oconee Watershed            | Paul Creek Energy Center, LLC and Plant Washington                 | 41.8%  | 42 million gallons per day                |
| Lower Flint Watershed             | Plant Mitchell, Bainbridge Power, and Longleaf Energy Station      | 44.4%  | 400 million gallons per day               |
| Savannah Watershed                | Warren County Biomass Energy Facility and Plant Vogtle Units 2 & 3 | 10.9%  | 19 million gallons per day                |
| Chattahoochee Watershed           | Units 1-3 of Plant McDonough                                       | 29%  | 0-90 million gallons per day <sup>a</sup> |

Sources: GAEPD Lower Flint, Middle Chattahoochee, Upper Oconee, Upper Ocmulgee, and Savannah Regional Water Plans

Note: <sup>a</sup> Different agriculture use scenarios result in this range of shortages

These shortages could have very negative effects on economic viability of these regions by constraining residential growth, agriculture and industry. Because thermoelectric power consumes such a large percentage of Georgia's water resources, there is great potential for conservation which will be discussed in the following sections.

### Methodology

A combination of sources was used to inform the statistical analysis of projected water use scenarios for the different power generating facilities. Basic information about each of the 11 planned facilities (see table1 below) was taken from Georgia's State Water Plan, which was compiled by the Environmental Protection Division of the Georgia Department of Natural Resources and adopted by the Georgia General Assembly in 2008 (EPD, 2009).

**Table 2.** Planned Energy Utility Facilities in Georgia

| Plant Name                                    | Capacity (MW) | Fuel Source/ Prime Mover    | Cooling Type <sup>a</sup> | County     | Planned Year of Operation      |
|---|---------------|-----------------------------|---------------------------|------------|--------------------------------|
| Plant Mitchell                                | 96            | Biomass/Steam Turbine       | OT                        | Dougherty  | 2013 (delayed)                 |
| McDonough Units 4&5                           | 1682          | Natural Gas/Steam Turbine   | CT                        | Cobb       | 2012 (delayed)                 |
| McDonough Unit 6                              | 841           | Natural Gas/Steam Turbine   | CT                        | Cobb       | 2013 (delayed)                 |
| Vogtle Unit 3                                 | 1102          | Nuclear/Steam Turbine       | CT                        | Burke      | 2016                           |
| Vogtle Unit 4                                 | 1102          | Nuclear/Steam Turbine       | CT                        | Burke      | 2017                           |
| Bainbridge Power                              | 170           | No. 2 Fuel Oil/Simple Cycle | N/A                       | Decatur    | b/w 2010 and 2015              |
| Paul Creek Energy Center, LLC                 | 225           | Natural Gas/Simple Cycle    | N/A                       | Washington | b/w 2015 and 2020              |
| Plant Washington                              | 850           | Coal/Steam Turbine          | CT                        | Washington | b/w 2010 and 2015              |
| Longleaf Energy Station                       | 1,200         | Coal/Steam Turbine          | CT2                       | Early      | b/w 2015 and 2020 <sup>3</sup> |
| Oglethorpe Power – Monroe County <sup>4</sup> | 1,200         | Natural Gas/Combined-Cycle  | CT                        | Monroe     | b/w 2015 and 2020              |
| Warren County Biomass Energy Facility         | 100           | Biomass/Steam Turbine       | CT                        | Warren     | 2015 <sup>5</sup>              |
| <b>Total</b>                                  |               |                             | <b>8,568 MW</b>           |            |                                |

Source: Georgia Environmental Protection Division, 2009.

Note: <sup>a</sup> Cooling Type Abbreviations = OT: Once-through (single pass), CT :Cooling Tower (re-circulated)

To determine the water demand coefficient for different electricity generating technologies, data from a study done by the National Renewable Energy Laboratory was compiled in a spreadsheet with the capacity (MW/hour) of each of the planned power plants and various water demand scenarios were calculated across nine different fuel sources, with different cooling processes and technologies under each source (Macknick et al, 2011). The following tables detail these factors.

**Table 3.** Consumption Factors for Renewable Technologies and Cooling Technology

| Fuel Type                      | Cooling              | Technology               | Median | Max   | Min  |
|--------------------------------|----------------------|--------------------------|--------|-------|------|
| PV                             | n/a                  | Utility Scale PV         | 26     | 33    | 0    |
| Wind                           | n/a                  | Wind Turbine             | 0      | 1     | 0    |
| Concentrated<br>Solar<br>Power | Tower                | Through                  | 865    | 1057  | 725  |
|                                |                      | Power Tower              | 786    | 860   | 740  |
|                                |                      | Fresnel                  | 1000   | 1000  | 1000 |
|                                | Dry                  | Through                  | 78     | 79    | 43   |
|                                |                      | Power Tower              | 26     | 26    | 26   |
|                                | Hybrid               | Through                  | 338    | 345   | 105  |
|                                |                      | Power Tower              | 170    | 250   | 90   |
|                                | n/a                  | Stirling                 | 5      | 6     | 4    |
| Biopower                       | Tower                | Steam                    | 553    | 965   | 480  |
|                                |                      | Biogas                   | 235    | 235   | 235  |
|                                | Once through<br>Pond | Steam                    | 300    | 300   | 30   |
|                                |                      | Steam                    | 390    | 480   | 300  |
|                                | Dry                  | Biogas                   | 35     | 35    | 35   |
|                                |                      |                          |        |       |      |
| Geothermal                     | Tower                | Dry Steam                | 176    | 1796  | 1796 |
|                                |                      | Flash (freshwater)       | 10     | 19    | 5    |
|                                |                      | Flash (geothermal fluid) | 2583   | 3100  | 2067 |
|                                |                      | Binary                   | 3600   | 3963  | 1700 |
|                                |                      | EGS                      | 4784   | 5147  | 2885 |
|                                | Dry                  | Flash (freshwater)       | 0      | 0     | 0    |
|                                |                      | Binary                   | 135    | 270   | 0    |
|                                |                      | EGS                      | 850    | 1778  | 300  |
|                                | Hybrid               | Binary                   | 221    | 368   | 74   |
|                                |                      | EGS                      | 1406   | 1999  | 813  |
| Hydropower                     | n/a                  | agg. in-stream res.      | 4491   | 18000 | 1425 |

Source: Macknick, et.al., National Renewable Energy Laboratory, 2011.



**Table 4.** Consumption Factors for Thermoelectric Power Fuel Types and Cooling Technology

|             |              |                       |     |      |     |
|-------------|--------------|-----------------------|-----|------|-----|
| Nuclear     | Tower        | Generic               | 672 | 845  | 581 |
|             | Once through | Generic               | 269 | 40   | 100 |
|             | Pond         | Generic               | 610 | 720  | 560 |
| Natural Gas | Tower        | Combined cycle        | 198 | 300  | 130 |
|             |              | Steam                 | 826 | 1170 | 662 |
|             |              | Combined cycle w/ CCS | 378 | 378  | 378 |
|             | Once through | Combined cycle        | 100 | 100  | 20  |
|             |              | Steam                 | 240 | 291  | 95  |
|             | Pond         | Combined cycle        | 240 | 240  | 240 |
|             | Dry          | Combined cycle        | 2   | 4    | 0   |
|             | Inlet        | Steam                 | 340 | 600  | 80  |
| Coal        | Tower        | Generic               | 687 | 1100 | 480 |
|             |              | Subcritical           | 471 | 664  | 394 |
|             |              | Supercritical         | 493 | 594  | 458 |
|             |              | IGCC                  | 372 | 439  | 318 |
|             |              | Subcritical w/ CCS    | 942 | 942  | 942 |
|             |              | Supercritical w/ CCS  | 846 | 846  | 846 |
|             | Once through | IGCC w/ CCS           | 540 | 558  | 522 |
|             |              | Generic               | 250 | 317  | 100 |
|             |              | Subcritical           | 113 | 138  | 72  |
|             |              | Supercritical         | 103 | 124  | 64  |
|             | Pond         | Generic               | 545 | 700  | 300 |
|             |              | Subcritical           | 779 | 804  | 737 |
|             |              | Supercritical         | 42  | 64   | 4   |


Source: Macknick, et.al., National Renewable Energy Laboratory, 2011.

These results were then analyzed based on the feasibility of different alternative energy technologies based on geographic location (county). The data regarding renewable energy potential was also taken from the National Renewable Energy Laboratory, which published data regarding wind, biomass, and various solar energy generation potential at the state and county level. Once the potential of different energy sources was determined, the water demand scenarios for different cooling processes and technologies within that energy source were analyzed to determine the best available technology in terms of lowest water consumption. For each planned facility the water consumption of the current planned technology was calculated and then feasible water saving alternatives were identified both in alternative fuel sources and the current technology if different cooling technologies were to be employed.

## Results

There are many opportunities for water conservation through changes in the planned technology across the 11 facilities. The greatest opportunities for savings occur at the the plants with the highest capacity, which include Units 4 & 5 at Plant McDonough, Units 2 & 3 at Plant Vogtle, Plant Long Leaf and Plant Oglethorpe, which all have generating capacities exceeding 1,000 MW. The greatest possible water savings (calculated by dividing the feasible technology with the lowest water use by the current planned technology's water use) averaged to a 99% savings at each of these facilities. The graph below illustrates the water consumption requirements of different fuel and cooling technologies applied to the conditions of each planned power plant.

**Figure 6.** Graph of Water Consumption of Fuel and Cooling Technology Alternatives for Planned Power Facilities in Georgia



Some of the water saving alternatives are very difficult to see on the graph because their use is so much lower than the current technologies. Utility scale solar photovoltaic (PV) electricity generation is one of these options. The solar PV potential for the entire state of Georgia is

---

between 5 and 5.5 on a scale of 3 (low potential) to 6.5 (high potential). For most facilities, concentrated solar power (CSP) which uses long, curved mirrors across a large land area to focus light on a pipe filled with a heat transfer liquid. This heated liquid is used to make steam and drive a turbine to generate electricity (DOE, 2010) was the alternative with the lowest water consumption. The exceptions to this were Units 4, 5 & 6 at plant McDonough, Paul Creek, and Oglethorpe, all of which would reap the greatest savings from using a combined cycle (generating steam and electricity) natural gas generator with dry cooling as opposed to a purely steam facility with tower cooling.

In a typical thermoelectric power plant, heat is removed from the cycle with a condenser. In order to remove the heat, cooling water is used. The two major types of cooling for power production are once-through cooling and closed-loop cooling; a minor type is termed dry cooling (Torcellini, 2003). Dry cooling is typically more water efficient, because dry cooling uses little or no water and needs less maintenance than cooling towers that require water. The cooling water (and related heat) is then discharged in to a river, a reservoir, or an ocean. However in some places this practice is being replaced by a process of evaporating a portion of the cooling tower which aims to minimize the environmental impacts from quickly dumping large amounts of heated water back into the stream. This results in significant consumptive use of water. For all of the planned facilities using coal, natural gas, and biomass a significant savings (96% on average), could be achieved through the adoption of dry cooling.

Biomass as a fuel source also yielded potential as a water saving technology with an average of 94% reduction in water consumption over current planned technologies at each of the facilities. However, there are significant barriers in technology, logistics, and policy to bring an electrical utility-scale biomass facility online. Plant Mitchell in Dougherty County has been trying to convert its coal fired facility into a biomass plant for the last five years, and has run into regulatory challenges as well as transportation issues in getting a steady supply of biomass feedstocks to the plant in a cost effective manner (PRN Newswire, 2011). Additionally, the consumptive water use requirements in this analysis only account for electricity generation, and do not take into consideration the water required for production of biomass feedstocks, which could be a potentially significant net consumptive use. Though natural gas and coal also have high water use requirements for production, unlike biomass these fuel sources are not produced in Georgia, and therefore would not have an impact on the water resources of the state (Stone, 2010).

Geothermal was only a feasible option at Plant Vogtle and Plant Warren because the geological conditions in Burke and Warren counties were the only places among all the locations of the planned power plants that had even a slight potential for geothermal energy. The savings could be significant, 99% reduction in water consumption, but given that the potential at these sites was only one ranking above “least favorable” it may not be a reliable alternative.

Hydropower is a very attractive option for Plant McDonough, Plant Vogtle, Plant Bainbridge, and Plant Long Leaf, all of which have untapped dam potential of 50-100 MW (NREL, 2013). Water flowing through the turbines and into the river is not considered consumptive because it is still immediately available for other uses. Increased surface area of the reservoir, when compared to the free flowing stream, does result in additional water evaporation from the surface, but the rate of evaporation would be dependent on a number or

---

variables, so for this analysis consumptive use is assumed to be zero. Therefore, opting for a hydroelectric dam over a fossil fuel powered facility would result in a 100% water savings.

Finally, wind power is not included in this analysis, not because it does not result in water savings (like hydro power is estimated to be near 100%), but because none of the planned facilities are located in regions of Georgia that have potential for wind energy generation.

## **Conclusions**

Based on this analysis of the water consumption rates of various fuels, technologies and cooling processes it can be concluded that the choice of cooling process has almost as much impact on the water use of planned power plants in Georgia as a choice in fuel source. The difference between the water consumption of a fossil fuel generator with dry cooling verses a concentrated solar or solar PV facility was not significant. Furthermore, in some cases the solar facility consumed more water. Moving forward, the next step would be to complete a cost benefit analysis for each of the feasible alternatives identified for each planned power plant. Considerations would need to be made for the environmental impacts of these plants, particularly since the fuel choices will have very different impacts, because of their emissions systems. Additionally, the potential for electricity rate changes in order to construct these facilities and operational life would need to be included in this analysis in order to give a more complete assessment of alternative means of electricity generation for future Georgia power plants.

## **References**

- Army Corps of Engineers. National Inventory of Dams. Available online at: <http://crunch.tec.army.mil/nid/webpages/nid.cfm>.
- "Condensers and Cooling Systems." Available online at: [http://www.energy.qld.gov.au/electricity/infosite/information sheets/condenser&cooling/info\\_sheet/condensers&cooling.htm..](http://www.energy.qld.gov.au/electricity/infosite/information sheets/condenser&cooling/info_sheet/condensers&cooling.htm..)
- Corso, R. Tear the Dam Down? H2Overview Water Resources Today. 1998. Available online at: <http://www.meadhunt.com/News/trash-dam.htm>.
- Cheyney, T. NREL Confirms 11% Conversion Efficiency for Solar Power Flexible CIGS PV Modules. PV TECH Available online at: [http://www.pv-tech.org/news/nrel\\_confirms\\_11\\_conversion\\_efficiency\\_for\\_solopower\\_flexible\\_cigs\\_pv\\_modul](http://www.pv-tech.org/news/nrel_confirms_11_conversion_efficiency_for_solopower_flexible_cigs_pv_modul).
- Davis, W. And Horrie, M. "Statewide Energy Sector Water Demand Forecast. 2010." Georgia Department of Natural Resources, Environmental Protection Division. Available online at: [http://www.georgiawaterplanning.org/documents/Energy\\_Tech\\_Memo\\_102910.pdf](http://www.georgiawaterplanning.org/documents/Energy_Tech_Memo_102910.pdf)
- "Delivering Big Solar with a Small Footprint." Solar Novus Today. 1 Dec. 2012. Available online at: [http://www.solarnovus.com/index.php?option=com\\_content&view=article&id=2860:delivering-big-solar-with-a-small-footprint&catid=76:>](http://www.solarnovus.com/index.php?option=com_content&view=article&id=2860:delivering-big-solar-with-a-small-footprint&catid=76:>).
- Epstein, P., J. Buonocore, K. Eckerle, M. Hendryx, B. Stout, R. Heinberg, R., ..., A. Glustrom, "Full cost accounting for the life cycle of coal." *Ecol. Econ Reviews*. N.Y. Acad. Sci. 2011.73-98
- Environmental Finance Center (EFC). Water and Sewer Rates and Rate Structures in Georgia. 2012. Georgia Environmental Finance Authority. Available online at: <http://www.efc.unc.edu/publications/2012/GA2012WaterSewerRatesReport.pdf>
- Fanning, J., And V. Trent. 2009. Water Use Trends in Georgia 1980-2005. Available online at: [http://pubs.usgs.gov/sir/2009/5002/pdf/2005\\_water\\_use\\_book\\_508\\_V4.pdf](http://pubs.usgs.gov/sir/2009/5002/pdf/2005_water_use_book_508_V4.pdf)

- 
- Farnsworth, R. K.; Thompson, E. S.; Peck, E. L. "Evaporation Atlas for the Contiguous 48 United States." National Weather Service: Washington, DC; Map 3. 1982. Available online at: [www.nws.noaa.gov/oh/hdsc/PMP\\_related\\_studies/TR33.pdf](http://www.nws.noaa.gov/oh/hdsc/PMP_related_studies/TR33.pdf)
- Georgia Department of Natural Resources. Environmental Protection Division. State Water Plan. 2008. Available online at: [http://www.georgiawaterplanning.org/documents/Energy\\_Forecast\\_ES\\_102910.pdf](http://www.georgiawaterplanning.org/documents/Energy_Forecast_ES_102910.pdf)
- Georgia Department of Natural Resources. Environmental Protection Division. Technical Memorandum on Georgia Statewide Energy Sector Water Demand Forecast 2008. Available online at: [http://www.georgiawaterplanning.org/documents/Energy\\_Tech\\_Memo\\_102910.pdf](http://www.georgiawaterplanning.org/documents/Energy_Tech_Memo_102910.pdf)
- Georgia Environmental Protection Division (GAEPD). Middle Ocmulgee Regional Water Plan. 2010. Available online at: [http://www.middleocmulgee.org/documents/MOC\\_Adopted\\_RWP\\_000.pdf](http://www.middleocmulgee.org/documents/MOC_Adopted_RWP_000.pdf)
- Georgia Environmental Protection Division (GAEPD). Upper Oconee Regional Water Plan. 2010. Available online at: [http://www.upperoconee.org/documents/UOC\\_Adopted\\_RWP\\_000.pdf](http://www.upperoconee.org/documents/UOC_Adopted_RWP_000.pdf)
- Georgia Environmental Protection Division (GAEPD). Middle Chattahoochee Regional Water Plan. 2010. Available online at: [http://www.middlechattahoochee.org/documents/MCH\\_Adopted\\_RWP\\_000.pdf](http://www.middlechattahoochee.org/documents/MCH_Adopted_RWP_000.pdf)
- Georgia Environmental Protection Division (GAEPD). Lower Flint Regional Water Plan. 2010. Available online at: [http://www.flintochlockonee.org/documents/LFO\\_Adopted\\_RWP\\_000.pdf](http://www.flintochlockonee.org/documents/LFO_Adopted_RWP_000.pdf)
- Jensen, V., & Lounsbury, E. Georgia Environmental Facilities Authority, Division of Energy Resources Assessment of energy efficiency potential in Georgia. San Francisco, CA: IFC Consulting. Available online at: <http://cleanefficientenergy.org/resource/georgia-assessment-energy-efficiency-potential>
- Mee, N., Miller, M. Here Comes the Sun: Solar Power Parity with Fossil Fuels, 36 *Wm. & Mary Env'tl. L. & Pol'y Rev.* 119 (2011), <http://scholarship.law.wm.edu/wmelpr/vol36/iss1/5>
- Macknick, J.; Newmark, R.; Heath, G.; Hallet, K. A Review of Operational Water Consumption and Withdrawal Factors for Electricity Generating Technologies. 2005. National Renewable Energy Laboratory. 2011. Available online at: <http://www.nrel.gov/docs/fy11osti/50900.pdf>
- National Renewable Energy Laboratory (NREL). River Atlas 2013. Available online at: [http://maps.nrel.gov/river\\_atlas](http://maps.nrel.gov/river_atlas)
- National Renewable Energy Laboratory (NREL). Dynamic Maps, GIS Data, and Analysis Tools - Geothermal Maps. Available online at: <http://www.nrel.gov/gis/geothermal.html>
- National Renewable Energy Laboratory (NREL). Dynamic Maps, GIS Data, and Analysis Tools - Solar Maps. Available online at: <http://www.nrel.gov/gis/solar.html>
- National Renewable Energy Laboratory (NREL). Dynamic Maps, GIS Data, and Analysis Tools - Biomass Maps. Available online at: <http://www.nrel.gov/gis/biomass.html>
- PR Newswire. Georgia Power to Delay Plant Mitchell Conversion to Biomass. Available online at: <http://www.prnewswire.com/news-releases-test/georgia-power-to-delay-plant-mitchell-conversion-to-biomass-81025432.html>
- Solar Energy System Descriptions, Tribal Energy and Environmental Clearinghouse. 2011 Available online at: <http://teeic.anl.gov/er/solar/restech/desc/index.cfm>
- Solley, W.; Pierce, R.; Perlman, H. Estimated Use of Water in the United States in 1995. United States Geological Survey. Available online at: [water.epa.gov/lawsregs/2000\\_08\\_02\\_316b\\_question\\_screener.pdf](http://water.epa.gov/lawsregs/2000_08_02_316b_question_screener.pdf)
- Stone, K. The potential impacts of biomass feedstock. *Bioresour Technol.* 2010 - PubMed NCBI. National Center for Biotechnology Information. Available online at: <http://www.ncbi.nlm.nih.gov/pubmed/19>
- Torcellini, P., Long, N., Judkoff, R. Consumptive Water Use for U.S. Power Production. National Renewable Energy Laboratory. 2003. Available online at: <http://www.nrel.gov/docs/fy04osti/33905.pdf>
- US Census Bureau. State and County Quick Facts. 2011. Available online at: <http://quickfacts.census.gov/qfd/states/13000.html>
- U.S. Department of Energy (DOE), Concentrated Solar Power Commercial Application Study: Reducing Water Consumption of Concentrated Solar Power Electricity Generation. 2010. Available online at:

---

[www.eere.energy.gov/solar/pdfs/csp\\_water\\_study.pdf](http://www.eere.energy.gov/solar/pdfs/csp_water_study.pdf)

U.S. Energy Information Agency (EIA). Energy Explained: Coal. 2011. Available online at:

[http://www.eia.gov/energyexplained/index.cfm?page=coal\\_prices](http://www.eia.gov/energyexplained/index.cfm?page=coal_prices)

U.S. Energy Information Agency (EIA), State Energy Data System .2012. Available online at:

[http://www.eia.gov/state/seds/hf.jsp?incfile=sep\\_sum\\_btu\\_eu.html](http://www.eia.gov/state/seds/hf.jsp?incfile=sep_sum_btu_eu.html)

U.S. Geological Survey (USGS). Preliminary Data Analysis Using Responses from the Detailed Industry Questionnaire: Phase II Cooling Water Intake Structures.2003. Available online at:

[water.epa.gov/lawsregs/.../2000\\_08\\_02\\_316b\\_question\\_screener.pdf](http://water.epa.gov/lawsregs/.../2000_08_02_316b_question_screener.pdf)

U.S. Geological Survey (USGS). Thermoelectric Power Water Use in Georgia, 2005 - USGS Georgia Water Science Center. Available online at: <http://ga.water.usgs.gov/infodata/wateruse/thermoelectric.html>

U.S. Geological Survey (USGS). Consumptive Water Use in Georgia, 2005 - USGS Georgia Water Science Center. 2009. Available online at: <http://ga.water.usgs.gov/infodata/wateruse/thermoelectric.html>

U.S. Geological Survey (USGS). Water Use in Georgia for 2005; Water-Use Trends 1980-2005. Scientific. 2009. Available online at: [http://pubs.usgs.gov/sir/2009/5002/pdf/2005\\_water\\_use\\_book\\_508\\_V4.pdf](http://pubs.usgs.gov/sir/2009/5002/pdf/2005_water_use_book_508_V4.pdf)

University of Georgia. Drought. Georgia Automated Environmental Monitoring Network. Available online at: <http://www.georgiaweather.net>